



TEST REPORT N. RA_2019_00004811

Filtration efficiency and retention capacity test
according to NF P 90-319 § 4 with derogation
Domestic swimming pools — Filtration groups and systems —
Test method for evaluating the filtration efficiency, the retention capacity
and the mechanical resistance

§ 4 Measure of filtration efficiency and retention capacity



Sample ref. AFM 21 ng (0,4 - 0,8mm) Sample 2

CUSTOMER IDENTIFICATION	
Company	DRYDEN AQUA
Address	BUTERFIELD INDUSTRIAL ESTATE, EH19 3JQ EDINBURGH UNITED KINGDOM
Contact	Mr Mike CAUSER
Purchase order nb	P05085

IFTS REFERENCES	
Purchase order nb	ARC_00005012
IFTS Order n.	AFF_00004159
Quotation n.	DEV_00005083.00

Written by
Emmanuelle CAQUINEAU

Validated and signed by
Test Manager

REVISION TABLE			
Date	Version	Reason for revision	Revision Description
10/08/2019	RA_2019_00004811	Initial release	

Confidential document prepared for the attention of DRYDEN AQUA

This report is only related to the specified product(s). Its copy is not authorised other than in its full form.

IFTS acknowledges only the digitally certified file in pdf format, before transmission to the customer. The digital certification of the report, conducted by the Chambersign certification, remains valid indefinitely as long as the file does not undergo any change. In the event of a dispute, only the file of the digitally certified report kept by IFTS will be considered as being the authentic version.

Siège social Téléphone : + 33 5 53 95 83 94
Rue Marcel Pagnol Fax : + 33 5 53 95 66 95
47510 FOULAYRONNES Email : ifts@ifts-sls.com

Association loi 1901 – JO du 31/05/1981
SIRET : 3227904030016, Agen – APE : 7112B
TVA : FR45 322790403

1 - SCOPE

DRYDEN AQUA has requested IFTS (Institut de la Filtration et des Techniques Séparatives) as per purchase order number P05085 to evaluate the performance of a specified number of samples according to NF P 90-319 §4 with derogation - Domestic swimming pools - Filtration groups and systems - Test method for evaluating the filtration efficiency, the retention capacity and the mechanical resistance §4 : Filtration efficiency and retention capacity.

The data contained in the following paragraphs establishes the report of the test performed on the sample identified in paragraph 2 of this document. A separate test report is issued for any other test requested as per the purchase order. This test has been performed with qualified personnel using thoroughly selected equipments in order to comply with test conditions summarized in paragraph 3 of this document. IFTS is accredited by the COFRAC to carry out tests and perform modular activities dealt with the ISO/IEC 17025.

2 - TEST SAMPLE

Sample ref.	IFTS ref.
AFM 21 ng (0,4 - 0,8mm) Sample 2	ECH_00031256
Grade 3 (2 - 4mm)	ECH_00031263



Sample ref. : AFM 21 ng (0,4 - 0,8mm) Sample 2 and Grade 3 (2 - 4mm)
supplied by DRYDEN AQUA

3- TEST CONDITIONS

3.1 Determination of the filtration efficiency and the retention capacity

The following test conditions have been applied :

- Standard : NF P 90-319 §4 with derogation*
- Multipass circulation of contaminant
- Test liquid : Filtered water
- Temperature : 23°C
- Contaminant : ISO CTD
- Initial contaminant concentration : 5 mg/L
- Test flow rate : 0,37 m³/h
- Test volume : 41,9 L
- Counting sizes : 1, 2, 4, 6, 8, 10, 20, 25 µm
- Flow speed : 20 m³/h.m²

*In terms of concentration, counting sizes and test volume

3.2 Picture and size of the installation

The main pump of the test circuit is installed upstream tested filter

- Column size H=205 cm ; d=15,4 cm ; Ω=0,0186 m²

- Filtration's beds sizes :

Height / Diameter(AFM 21 ng (0,4 - 0,8mm) Sample 2) : H=85 cm / d=15,4 cm

Height / Diameter(Grade 3 (2 - 4mm) Sample 9) : H=15 cm / d=15,4 cm



Fig 1. : Picture of test rig

4- TEST RESULTS

4.1 Test end criteria

	Test end criteria	Actual value	End criteria
Final ΔP - Initial ΔP (kPa)	70 kPa	3	No
Test duration (min)	≥ 360	362	Yes

4.2 Filtration performances

Retention capacity (g)	Filtration ratio 80% (μm)	Filtration efficiency 45 μm (%)	Comments
11,39	< 1	> 98,9	/

The global filtration rating and the global filtration efficiency are calculated based on total counting data relative to all the test duration at 5 mg/L.

4.3 Detailed test results

Test identification

Test date : 03/10/2019	Operator : ML	IFTS n. : ECH_00031256
------------------------	---------------	------------------------

Customer reference

Filter ref. : AFM 21 ng (0,4 - 0,8mm) Sample 2
--

Test parameters

Test fluid : Filtered water	Test dust : ISO CTD	Batch n. : 13388C
-----------------------------	---------------------	-------------------

Test results

Parameters		Contaminant injection			Particle counting				
Test flow rate (m3/h)	0,37	Flow rate (L/h)	Concentration (mg/L)			Counter	Sensor	Flow rate (mL/min)	Volume (mL)
Temperature (°C)	23,4		Initial	Final	Average				
Concentration (mg/L)	5,2	10,02	202	181	191,5	PAMAS 2132	WaterViewer	25	25
Test duration (min)	362								

Initial cleanliness (#/mL)

Particle number/mL	Sizes (µm)	> 1	> 2	> 4	> 6	> 8	> 10	> 20	> 25
	Upstream	110,52	75,64	33,6	12,96	7,48	5,68	2,4	1,76
	Downstream	42	23,84	10,16	5,12	4,08	3,88	3,32	2,92

Filtration efficiency and Particle number (#/mL)



Sizes (µm)		> 1	> 2	> 4	> 6	> 8	> 10	> 20	> 25								
Upstream	E (%)	12702	94,6	8737	96,9	3359	99,3	1338	99,9	559	99,9	274	99,9	20	99	8	98,9
Downstream		684		270		25		2		0		0		0		0	

Retention capacity

Final concentration (mg/L) :	4,38	Volume (L) :	41,9
Injected mass (g) :	11,6	Non-retained mass (g) :	0,18

Retention capacity (g) : 11,39

Retention capacity :	CR= 11,4 g
Filtration efficiency (45µm) :	E45= > 98,9 %
Filtration ratio (80%) :	S80= < 1 µm







Fig.6 : Test flow rate vs. Differential pressure




Fig.7 : Average efficiency vs. Particle size

